

Beste bewoner,

Hierbij willen we u informeren over technisch onderhoud dat heeft plaatsgevonden in de technische ruimte bij u in het gebouw. Vanwege een pomp die niet goed functioneerde had u in het weekend 11-12 mei geen warm water of lauw water.

De pomp is gisteren vervangen en warm water is weer beschikbaar. Mocht u nog een vraag hebben over dit onderhoud horen we het graag.

Met vriendelijke groet,

Team klantenservice



Onderdeel van  
**inwarmte** 

T: 085 - 130 48 31

E: [vrAGEN@inwarmte.nl](mailto:vrAGEN@inwarmte.nl)

W: [www.warmherenvanbreda.nl](http://www.warmherenvanbreda.nl)

Dear Resident,

We would like to inform you about technical maintenance that has taken place in the technical room of your building. Due to a malfunctioning pump, you had no hot water or lukewarm water over the weekend of the 11<sup>th</sup> -12<sup>th</sup> of May.

The pump was replaced yesterday and hot water is now available again. If you have any questions about this maintenance, please let us know.

Kind regards,

Team customer service



Onderdeel van  
**inwarmte** 

T: **085 - 130 48 31**

E: [vragen@inwarmte.nl](mailto:vragen@inwarmte.nl)

W: [www.warmherenvanbreda.nl](http://www.warmherenvanbreda.nl)